

From: dbofinger@kemron.com
Sent: 6/7/2012 1:56:17 PM

To: "Richard Fetzer/R3/USEPA/US@EPA" <Fetzer.Richard@epamail.epa.gov>
CC: "Joanna Mcdonald/R3/USEPA/US@EPA" <Mcdonald.Joanna@epamail.epa.gov>
Subject: [Ex. 6 - Personal Privacy] RD treatment systems

Rich,

I checked the water treatment system at [Ex. 6 - Personal Privacy] Rd like you asked me to do yesterday.

Both of the trailers on the property have the same treatment system in them. It looks like two sand units, a chlorine injection tank, and a carbon cell. From what I am told by the residents they have added chlorine or bleach (the occupant of one trailer said bleach and the occupant of other trailer said chlorine) recently, and the system automatically back flushes itself.

Also the water line from the Potable water trailers are hooked to it to feeds this system before going to a faucet or spigot in the trailer. This is the water line that was hooked up to the Cabot supplied water buffalo's and at one time was hooked to the properties well.

I have enclosed some pictures of the systems. The chlorination tank is approximately 35 gallon in size and I was told by the resident of the old trailer that when the tank shows a level of ten gallons that they add 2 gallons of bleach / chlorine to the tank and refill it with water

The Carbon cell head picture is hard to see but there is a timer on it for back flushing the unit on a predetermined schedule and [Ex. 6 - Personal Privacy] who used to live in the old trailer and now resides in the trailer that used to be occupied by [Ex. 6 - Personal Privacy], says that neither the carbon or sand cells at either systems has not been changed out since the systems were installed when this all started 3 or 4 years ago. I also asked [Ex. 6 - Personal Privacy] if he has any literature for the system and he replied that maybe [Ex. 6 - Personal Privacy] does but he has never seen any.

The systems were installed by Water Medic in Clarks Summit, their phone number is (888)- 442-0349

The lighting was low and the pictures taken with a cell phone are not the best but I hope that this answers your question about the systems.

Dave Bofinger
Response Manager
Kemron Environmental Services Inc
1359-A Ellsworth Industrial Blvd
Atlanta, GA 30318
e mail- dbofinger@Kemron.com
Cell phone- 404 725 3257
Phone-404 636 0928 Fax 404 636 7162
Visit us at www.kemron.com

Know Safety, No Accidents

P Before printing, think about ENVIRONMENTAL responsibility

The information contained in this email may be confidential and/or legally privileged. It has been sent for the sole use of the intended recipient(s). If the reader of this message is not an intended recipient, you are hereby notified that any unauthorized review, use, disclosure, dissemination, distribution, or copying of this communication, or any of its contents, is strictly prohibited. If you have received this communication in error, please reply to the sender and destroy all copies of the message. To contact us directly, send to postmaster@kemron.com. Thank you.

- 652 treatment system chlorination tank.jpg - 652 treatment system carbon cell label.jpg - 652 treatment
system 1.jpg - 652 carbon cell head.jpg